

# Water Testing Results -

# Cedaroak Park Primary School

**Action Level is 15 parts per billion (ppb)**

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Room 2 Classroom Faucet	19220101-001CF	5/17/2023	36.3
Room 2 Classroom Drinking Fountain	19220101-002DW	5/17/2023	6.8
Room 3 Classroom Faucet	19220101-003CF	5/17/2023	1.8
Room 3 Classroom Drinking Fountain	19220101-004DW	5/17/2023	2.8
Room 4 Classroom Faucet	19220101-005CF	5/17/2023	2.9
Room 4 Classrom Drinking Fountain	19220101-006DW	5/17/2023	1.7
Room 5 Classroom Faucet	19220101-007CF	5/17/2023	3.0
Room 5 Classroom Drinking Fountain	19220101-008DW	5/17/2023	4.3
Room 6 Classroom Faucet	19220101-009CF	5/17/2023	1.7
Room 6 Classroom Drinking Fountain	19220101-010DW	5/17/2023	1.8
Room 7 Classroom Faucet	19220101-011CF	5/17/2023	6.1
Room 7 Classroom Drinking Fountain	19220101-012DW	5/17/2023	1.2
Room 8 Classroom Faucet	19220101-013CF	5/17/2023	1.5
Room 8 Classroom Drinking Fountain	19220101-014DW	5/17/2023	4.6
Room 9 Classroom Faucet	19220101-015CF	5/17/2023	3.7
Room 9 Classroom Drinking Fountain	19220101-016DW	5/17/2023	ND
Room 10 Classroom Faucet	19220101-017CF	5/17/2023	ND
Room 10 Classroom Drinking Fountain	19220101-018DW	5/17/2023	1.1
Room 16 Staff Work room	19220100-019SF	5/17/2023	ND
Room 18 Health room Bathroom	19220100-020BF	5/17/2023	ND
Room 19 Health room Faucet	19220100-021NS	5/17/2023	ND
Hall 20 Drinking Fountain	19220100-022DW	5/17/2023	ND
Hall 20 Water Bottle Filling Station	19220100-023WB	5/17/2023	ND
Room 22 Boys Restroom	19220100-024BF	5/17/2023	ND
Room 23 Restroom	19220100-025BF	5/17/2023	ND
Room 24 Girls Restroom	19220100-026BF	5/17/2023	ND
Room 25 Staffroom instant hot water	19220100-063SF	5/17/2023	ND
Room 25 Staffroom Faucet	19220100-027SF	5/17/2023	ND
Room 30 Restroom	19220100-028BF	5/17/2023	ND
Room 32 Kitchen faucet "NE facing handwashing sink"	19220100-029KF	5/17/2023	5.5
Room 32 Kitchen faucet "West facing handwashing sink"	19220100-030KF	5/17/2023	3.7
Room 32 Kitchen faucet "West facing pot washing sink, right"	19220100-031KF	5/17/2023	2.0
Room 32 Kitchen faucet "West facing pot washing sink, center"	19220100-032KF	5/17/2023	ND
Room 32 Kitchen faucet "West facing pot washing sink, left"	19220100-033KF	5/17/2023	1.1
Room 32 Kitchen faucet "South facing pot washing sink"	19220100-034KF	5/17/2023	ND
Room 32 Kitchen faucet "East facing hand washing sink"	19220100-035KF	5/17/2023	2.4
Room 35A Room off the Cafeteria	19220100-036SF	5/17/2023	ND
Room 35 Cafeteria Water Chiller	19220100-037WC	5/17/2023	ND
Room 41 Gymnasium Water Chiller	19220100-038WC	5/17/2023	ND
Room 46 Activity Area Drinking Fountain "Far left, Drinking Fountain"	19220100-039DW	5/17/2023	ND
Room 46 Activity Area Handwashing sink "Left, hand washing Bradly station "	19220100-040CF	5/17/2023	ND
Room 46 Classroom Faucet "Center left, Classroom faucet "	19220100-041CF	5/17/2023	ND
Room 46 Classroom Faucet "Center right , Classroom faucet"	19220100-042CF	5/17/2023	ND
Room 46 Classroom Faucet "Far right, Classroom faucet"	19220100-043CF	5/17/2023	1.2
Room 47 Boys Bathroom faucet	19220100-044BF	5/17/2023	ND
Room 50A Bathroom faucet	19220100-045BF	5/17/2023	ND
Room 50 Activity Area Faucet "Far right, Classroom faucet"	19220100-046CF	5/17/2023	ND
Room 50 Activity Area Faucet "Center right, Classroom faucet"	19220100-047CF	5/17/2023	ND
Room 50 Activity Area Faucet "Center left, Classroom faucet"	19220100-048CF	5/17/2023	1.3
Room 50 Activity Area faucet "Left, hand washing Bradly station"	19220100-049CF	5/17/2023	ND
Room 50 Activity Area Drinking Fountain "Far left, Drinking Fountain"	19220100-050DW	5/17/2023	ND
Room 57 Activity Area Drinking Fountain "Far right, Drinking Fountain"	19220100-051DW	5/17/2023	ND
Room 57 Activity Area faucet " Right, hand washing Bradly station"	19220100-052CF	5/17/2023	ND
Room 57 Activity Area Faucet "Right center, Classroom faucet"	19220100-053CF	5/17/2023	ND
Room 57 Activity Area Faucet "Left center, Classroom faucet"	19220100-054CF	5/17/2023	ND
Room 57 Activity Area Faucet "Far left, Classroom faucet"	19220100-055CF	5/17/2023	ND
Room 57A Bathrrom faucet	19220100-056BF	5/17/2023	ND
Room 59 Boys Bathroom faucet	19220100-057BF	5/17/2023	ND
Room 64 Activity Area Drinking Fountain "Far right, Drinking fountain"	19220100-058DW	5/17/2023	ND
Room 64 Activity Area faucet "Right, hand washing, Bradly station"	19220100-059CF	5/17/2023	ND
Room 64 Activity Area faucet "Center right, Classroom faucet"	19220100-060CF	5/17/2023	1.1
Room 64 Activity Area faucet "Center left, Classroom faucet"	19220100-061CF	5/17/2023	ND

Room 64 Activity Area faucet "Far left, Classroom faucet"	19220100-062CF	5/17/2023	6.4
Outside room 1 "keyed"	19220100-064OS	Exempt	Exempt
Outside room 4 "keyed"	19220100-065OS	Exempt	Exempt
Outside room 7, at the play structure, "locked"	19220100-066OS	Exempt	Exempt
Outside room 8 "keyed"	19220100-067OS	Exempt	Exempt
Outside room 7 "keyed"	19220100-068OS	Exempt	Exempt
Outside room 3 "keyed"	19220100-069OS	Exempt	Exempt
Outside room 26 "keyed"	19220100-070OS	Exempt	Exempt
Outside room 13 "keyed"	19220100-071OS	Exempt	Exempt
Outside Drinking fountain, at the play ground "Out of Service"	19220100-072DW	Out of Service	Out of Service
Outside Drinking fountain, at the play ground "Out of service"	19220100-073DW	Out of Service	Out of Service
Outside room 66 "keyed"	19220100-074OS	Exempt	Exempt
Cedaroak Park garden, right side of gate "Signage"	19220100-075OS	Exempt	Exempt
Cedaroak Park garden, left side of sink, "Signage"	19220100-076OS	Exempt	Exempt
<b>Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing</b>			
<b>RETESTS</b>			
Room 2 Classroom Faucet	19220101-001CF	5/31/2023	1.2
ND = Non Detect - Lead level is below the set detection limits			of 1 ppb