

Water Testing Results

Stafford Primary School

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Room 037 Nurses Station sink	19220300-001NS	04/26/23	ND
Room T002 Staff Bathroom sink	19220300-002BF	04/06/23	1.50
Room 031 Staff Workroom Faucet	19220300-003SF	04/26/23	ND
Hall C004 Drinking Fountain "outside room 031"	19220300-004DW	04/26/23	2.85
Room 030 Classroom Faucet	19220300-005CF	04/26/23	1.68
Room 029 Classroom Faucet	19220300-006CF	04/26/23	3.65
Room 029 Classroom Drinking Fountain	19220300-007DW	04/26/23	ND
Room 028 Classroom Faucet	19220300-008CF	04/26/23	4.11
Room 028 Classroom Drinking Fountain	19220300-009DW	04/26/23	1.32
Corr. C004 Bathroom Faucet "Located between T005 Boys & T004 Girls Bathrooms"	19220300-010BF	04/26/23	1.71
Room T005A Bathroom Faucet "Single unisex bathroom"	19220300-011BF	04/26/23	1.05
Room 027 Classroom Faucet	19220300-012CF	04/26/23	3.03
Room 027 Classroom Drinking Fountain	19220300-013DW	04/26/23	3.51
Room 026 Classroom Faucet	19220300-014CF	04/26/23	2.65
Room 026 Classroom Drinking Fountain	19220300-015DW	04/26/23	ND
Room 023 Classroom Faucet	19220300-016CF	04/26/23	1.19
Room 023 Classroom Drinking Fountain	19220300-017DW	04/26/23	241.00
Room 022 Classroom Faucet	19220300-018CF	04/26/23	3.25
Room 022 Classroom Drinking Fountain	19220300-019DW	04/26/23	1.00
Room 021 Classroom Faucet	19220300-020CF	04/26/23	0.92
Room 021 Classroom Drinking Fountain	19220300-021DW	04/26/23	ND
Room 020 Classroom Faucet	19220300-022CF	04/26/23	1.53
Room 020 Classroom Drinking Fountain	19220300-023DW	04/26/23	ND
Room 019 Classroom Faucet	19220300-024CF	04/26/23	1.33
Room 019 Classroom Drinking Fountain	19220300-025DW	04/26/23	2.23
Room 018 Classroom Faucet	19220300-026CF	04/26/23	1.09
Room 018 Classroom Drinking Fountain "Plumbing isn't hooked up"	19220300-027DW	Out of service	3.89
Corridor C008, Drinking Fountain. "Located outside room 018"	19220300-028DW	04/26/23	ND
Room 017 Classroom Faucet	19220300-029CF	04/26/23	ND
Room 017 Classroom Drinking Fountain	19220300-030DW	04/26/23	3.03
Room 016 Classroom Faucet	19220300-031CF	04/26/23	1.14
Room 016 Classroom Drinking Fountain	19220300-032DW	04/26/23	1.89
Room T009 Boys Bathroom Sink "Restrooms closest to the Gym. South side of building"	19220300-033BF	04/26/23	1.63
Corridor C010 Drinking Fountain. "Located between T008 girls and T009 boys bathrooms by Gym"	19220300-034DW	04/26/23	ND
Room T008 Girls Bathroom Sink "Restroom closest to the Gym. South side of building"	19220300-035BF	04/26/23	1.63

Room 012 Gym Drinking Fountain "Southeast facing"	19220300-036DW	04/26/23	ND
Room 012 Gym Drinking Fountain "Northwest facing"	19220300-037DW	04/26/23	ND
T007 Girls bathroom sink "Out of service.Room is used for storage only"	19220300-091BF	Out of service	
T008 Boys bathroom sink "Out of service.Room is used for storage only"	19220300-092BF	Out of service	
Corridor C008 Water Bottle Filling Station "Located outside room 014"	19220300-038WB	04/26/23	ND
Corridor C008 Water cooler "Located outside room 014"	19220300-081WC	04/26/23	ND
Room 014 Classroom Faucet	19220300-039CF	04/26/23	1.51
Room 014 Classroom Drinking Fountain	19220300-040DW	04/26/23	2.93
Room 010 Classroom Faucet	19220300-041CF	04/07/23	5.40
Room 010 Classroom Drinking Fountain	19220300-042DW	04/07/23	4.30
Room 013 Staffroom Sink	19220300-043SF	04/26/23	ND
Room 013 Staffroom Drinking Fountain	19220300-044DW	04/26/23	5.83
Room 009 Classroom Faucet	19220300-045CF	04/07/23	4.90
Room 009 Classroom Drinking Fountain	19220300-046DW	04/07/23	1.70
Room 008 Classroom Faucet	19220300-047CF	04/26/23	1.02
Room 008 Classroom Drinking Fountain	19220300-048DW	04/26/23	3.18
Room 007 Classroom Faucet	19220300-049CF	04/26/23	1.22
Room 007 Classroom Drinking Fountain	19220300-050DW	04/26/23	4.25
Room 006 Classroom Faucet	19220300-051CF	04/26/23	ND
Room 006 Classroom Drinking	19220300-052DW	04/26/23	3.15
Room T010 Bathroom Faucet "Single unisex bathroom"	19220300-053BF	04/26/23	1.28
Room T011 Bathroom Faucet "Single unisex bathroom"	19220300-054BF	04/26/23	ND
Room T012 Boys Bathroom "Located in West side of building"	19220300-055BF	04/26/23	1.10
Room T013 Girls Bathroom "Located in West side of building "	19220300-056BF	04/26/23	1.44
Room 005 Classroom Faucet	19220300-057CF	04/26/23	ND
Room 005 Classroom Drinking Fountain	19220300-058DW	04/26/23	1.59
Room 004 Classroom Faucet	19220300-059CF	04/26/23	1.20
Room 004 Classroom Drinking Fountain	19220300-060DW	04/26/23	ND
Room 003 Classroom Faucet	19220300-061CF	04/26/23	1.34
Room 003 Classroom Drinking Fountain	19220300-062DW	04/26/23	ND
Room 002 Classroom Faucet	19220300-063CF	04/26/23	1.17
Room 002 Classroom Drinking Fountain	19220300-064DW	04/26/23	ND
Room 001 Classroom Faucet	19220300-065CF	04/26/203	1.70
Room 001 Classroom Drinking Fountain	19220300-066DW	04/26/23	ND
Corridor C003 Drinking Fountain "Located outside room 001"	19220300-067DW	04/26/23	2.05
Room 044 "Multi-purpose room" Classroom Drinking Fountain "Outside room 042A, center"	19220300-068DW	04/26/23	2.09
Room 044 "Muti-purpose room" Classroom Drinking Fountain "Outside room 042A,Right "	19220300-069DW	04/26/23	1.24

Room 044 "Multi-purpose room" Classroom Faucet "Hand washing station"	19220300-070CF	04/26/23	ND
Room 044 "Multi-purpose room" Water bottle filler "Outside room 042A, Left"	19220300-082WB	04/26/23	ND
Room 042A Staff Faucet "Custodial office's"	19220300-071SF	04/26/23	3.12
Room T014 Bathroom Faucet "Located across from 042A custodial office's, Left"	19220300-072BF	04/26/23	1.60
Room T014 Bathroom Faucet "Located across from 042A custodial office's, Right"	19220300-073BF	04/26/23	3.13
Room 043 Kitchen South facing handwashing sink	19220300-074KF	04/26/203	4.27
Room 043 Kitchen South facing pot washing sink	19220300-075KF	04/26/23	1.85
Room 043 Kitchen East facing hand washing sink	19220300-076KF	04/26/23	5.13
Room 043 Kitchen North facing pot washing sink	19220300-077KF	04/26/23	4.46
Room T015 Single Bathroom Faucet "Off the Multi-purpose room, girls bathroom"	19220300-078BF	04/26/23	1.50
Room T016 Single Bathroom Faucet "Off the Muti-purpose room, boys bathroom"	19220300-079BF	04/26/23	1.68
Room 047B Work Room Faucet	19220300-080SF	04/26/23	5.23
Courtyard A Outside spigot	19220300-083OS	04/26/23	2.16
Courtyard B outside spigot"keyed"	19220300-084OS	Exempt	
Courtyard C Outside spigot	19220300-085OS	04/26/23	24.40
Outside room 030 outside spigot	19220300-086OS	Exempt	
Outside room 019 outside spigot "keyed"	19220300-087OS	Exempt	
Outside Corridor 010 outside spigot "keyed"	19220300-088OS	Exempt	
Outside room 006 outside spigot "keyed"	19220300-089OS	Exempt	

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS			
Room 023 Classroom Drinking Fountain	1922-0300-017DW	05/09/23	13.3
Courtyard C Outside spigot	19220300-085OS	06/20/23	ND

ND = Non Detect - Lead level is below the set detection limits of 1 ppb