

## Lead in Water Test Results Summary: Boones Ferry Primary

### Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.  
*Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.*
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

### Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

| Fixture Location Description                                      | Fixture ID #   | Initial Test Date | Initial Test Result (ppb) | Initial Level | Final Retest Date | Final Test Result (ppb) | Final Level |
|-------------------------------------------------------------------|----------------|-------------------|---------------------------|---------------|-------------------|-------------------------|-------------|
| 108- Nurses station faucet. Health room                           | 19221200-001NS | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 109-Bathroom faucet. Nurses station bathroom                      | 19221200-002BF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 110- Staff faucet. Staff Lounge instant hot water. Left           | 19221200-003SF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 110- Staff faucet. Staff Lounge. Right                            | 19221200-004SF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 112- Staff bathroom. Bathroom faucet. Left                        | 19221200-005BF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 111- Staff bathroom. Bathroom faucet. Right                       | 19221200-006BF | 3/12/2025         | 1.4                       | Low           |                   |                         |             |
| 113- Work room. Staff faucet                                      | 19221200-007SF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| Hall 121- Water bottle filler. Above fixture                      | 19221200-008WB | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 19221200-009WC. Center                                            | 19221200-009WC | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| Hall 121- Water cooler- Located below 19221200-008WB. Right       | 19221200-010WC | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| Hall 121- Water cooler. Left                                      | 19221200-011SF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 125- Media Office. Staff faucet                                   | 19221200-012KF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 141- Kitchen faucet. West facing hand washing station. Right      | 19221200-014KF | 3/12/2025         | 9.3                       | Moderate      |                   |                         |             |
| 141- Kitchen faucet. Pot sprayer West facing. Left                | 19221200-015KF | 3/12/2025         | 1.9                       | Low           |                   |                         |             |
| 141- Kitchen faucet. Prep sink South facing                       | 19221200-016KF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 141- Kitchen faucet. Prep sink North facing. Right                | 19221200-017KF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 141- Kitchen faucet. Prep sink North facing. Left                 | 19221200-018BF | 3/12/2025         | 1                         | Low           |                   |                         |             |
| 147- Bathroom faucet. Toilet is off the kitchen                   | 19221200-019BF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 128- Girl's bathroom. Bathroom faucet                             | 19221200-020BF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 129- Boy's bathroom. Bathroom faucet                              | 19221200-021BF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 709- Toilet. Bathroom faucet                                      | 19221200-022BF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 710- Toilet. Bathroom faucet                                      | 19221200-023CF | 3/12/2025         | 3                         | Low           |                   |                         |             |
| 701- Student Commons. Classroom faucet. Right                     | 19221200-024CF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 701- Student Commons. Classroom faucet. Left                      | 19221200-025DW | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 801- Classroom drinking water. Right                              | 19221200-026CF | 3/12/2025         | 1.4                       | Low           |                   |                         |             |
| 801- Classroom faucet. Left                                       | 19221200-027CF | 3/12/2025         | 1.9                       | Low           |                   |                         |             |
| 802- Classroom faucet. Left                                       | 19221200-028DW | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 802-Classroom drinking water. Right                               | 19221200-029CF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 803- Classroom faucet. Left                                       | 19221200-030DW | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 803-Classroom drinking water. Right                               | 19221200-031CF | 3/12/2025         | 1.3                       | Low           |                   |                         |             |
| 804- Classroom faucet. Left                                       | 19221200-032DW | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 804-Classroom drinking water. Right                               | 19221200-033BF | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| Between 715 Boys restroom and 716 Girls restroom. Bathroom faucet | 19221200-034CF | 3/12/2025         | 1.5                       | Low           |                   |                         |             |
| 1001- Classroom faucet. Left                                      | 19221200-035DW | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 1001- Classroom drinking water                                    | 19221200-036CF | 3/12/2025         | 1.4                       | Low           |                   |                         |             |
| 1002- Classroom faucet. Left                                      | 19221200-037DW | 3/12/2025         | 7.9                       | Moderate      |                   |                         |             |
| 1002-Classroom drinking water. Right                              | 19221200-038CF | 3/12/2025         | 4.2                       | Low           |                   |                         |             |
| 1003- Classroom faucet. Left                                      | 19221200-039DW | 3/12/2025         | ND                        | Non-Detect    |                   |                         |             |
| 1003-Classroom drinking water                                     |                |                   |                           |               |                   |                         |             |

|                                                                                     |                |           |      |             |  |  |  |
|-------------------------------------------------------------------------------------|----------------|-----------|------|-------------|--|--|--|
| 1004- Classroom faucet. Left                                                        | 19221200-040CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1004- Classroom drinking water. Right                                               | 19221200-041DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
|                                                                                     |                | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 726- Bathroom faucet. Staff bathroom in Gym 702                                     | 19221200-043BF |           |      |             |  |  |  |
| Hall 721- Bathroom faucet. Located between Boys restroom 724 and Girls restroom 723 | 19221200-045BF | 3/12/2025 | 4.4  | Low         |  |  |  |
| Hall 721- Drinking water. Right                                                     | 19221200-046DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| Between 706 Boys restroom and 707 Girls restroom. Bathroom faucet                   | 19221200-048BF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1101- Classroom faucet. Left                                                        | 19221200-049CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1101- Drinking water. Right                                                         | 19221200-050DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1102- Classroom faucet. Left                                                        | 19221200-051CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1102- Drinking water. Right                                                         | 19221200-052DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1103- Classroom faucet. Left                                                        | 19221200-053CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1103- Drinking water. Right                                                         | 19221200-054DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1104- Classroom faucet. Left                                                        | 19221200-055CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 1104- Drinking water. Right                                                         | 19221200-056DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 901- Classroom faucet. Left                                                         | 19221200-057CF | 3/12/2025 | 3.1  | Low         |  |  |  |
| 901- Drinking water. Right                                                          | 19221200-058DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 902- Classroom faucet. Left                                                         | 19221200-059CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 902- Drinking water. Right                                                          | 19221200-060DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 903 - Classroom faucet. Left                                                        | 19221200-061CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 903- Drinking water. Right                                                          | 19221200-062DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 904- Classroom faucet. Left                                                         | 19221200-063CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 904- Drinking water. Right                                                          | 19221200-064DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 703- Kitchen faucet. Satellite Kitchen. Hand washing sink                           | 19221200-065KF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
|                                                                                     |                | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 703- Kitchen faucet. Satellite Kitchen. Prep sink                                   | 19221200-066KF |           |      |             |  |  |  |
| 701- Water cooler. Student commons. Right                                           | 19221200-067WC | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 701- Water cooler. Student commons. Left                                            | 19221200-068WC | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 201- Water cooler. Student commons. Right                                           | 19221200-069WC | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 201- Water cooler. Student commons. Left                                            | 19221200-070WC | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 203- Satellite kitchen. Kitchen faucet. Hand washing sink                           | 19221200-071KF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
|                                                                                     |                | 3/12/2025 | 1.7  | Low         |  |  |  |
| 203- Satellite kitchen. Kitchen faucet. Prep sink                                   | 19221200-072KF |           |      |             |  |  |  |
| 301- Classroom faucet. Left                                                         | 19221200-073CF | 3/12/2025 | 1    | Low         |  |  |  |
| 301- Drinking water. Right                                                          | 19221200-074DW | 3/12/2025 | Nd   | Non-Detect  |  |  |  |
| 302- Classroom faucet. Left                                                         | 19221200-075CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 302- Drinking water. Right                                                          | 19221200-076DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 303- Classroom faucet. Left                                                         | 19221200-077CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 303- Drinking water. Right                                                          | 19221200-078DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 304- Classroom faucet. Left                                                         | 19221200-079CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 304- Drinking water. Right                                                          | 19221200-080DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
|                                                                                     |                | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| Bathroom faucet. Between girl's 207 and boy's 206                                   | 19221200-081BF |           |      |             |  |  |  |
| 501- Classroom faucet. Left                                                         | 19221200-082CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 501- Drinking water. Right                                                          | 19221200-083DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 502- Classroom faucet. Left                                                         | 19221200-084CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 502- Drinking water. Right                                                          | 19221200-085DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 503- Classroom faucet. Left                                                         | 19221200-086CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 503- Drinking water. Right                                                          | 19221200-087DW | 3/12/2025 | 1.3  | Low         |  |  |  |
| 504- Classroom faucet. Left                                                         | 19221200-088CF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 504- Drinking water. Right                                                          | 19221200-089DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
|                                                                                     |                | 3/12/2025 | 1.5  | Low         |  |  |  |
| 221- Bathroom faucet. Staff bathroom. Single user                                   | 19221200-090BF |           |      |             |  |  |  |
| 222- Bathroom faucet. Girl's bathroom.                                              | 19221200-092BF | 3/12/2025 | 3.8  | Low         |  |  |  |
| Between boy's bathroom 223 and girl's bathroom                                      |                | 3/12/2025 |      |             |  |  |  |
| 222. Drinking water. Left                                                           | 19221200-094DW |           |      |             |  |  |  |
| 223- Bathroom faucet. Boy's bathroom                                                | 19221200-095BF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| Bathroom faucet. Between Boy's 215 and Girl's 216                                   | 19221200-096BF | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 604- Classroom faucet. Left                                                         | 19221200-097CF | 3/12/2025 | 2.3  | Low         |  |  |  |
| 604- Drinking water. Right                                                          | 19221200-098DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |
| 603- Classroom faucet. Left                                                         | 19221200-099CF | 3/12/2025 | 9.2  | Moderate    |  |  |  |
| 603- Drinking water. Right                                                          | 19221200-100DW | 3/12/2025 | 17.1 | Action Req. |  |  |  |
| 602- Classroom faucet. Left                                                         | 19221200-101CF | 3/12/2025 | 1.1  | Low         |  |  |  |
| 602- Drinking water. Right                                                          | 19221200-102DW | 3/12/2025 | ND   | Non-Detect  |  |  |  |

|                                               |                |           |     |            |  |  |  |
|-----------------------------------------------|----------------|-----------|-----|------------|--|--|--|
| 601- Classroom faucet. Left                   | 19221200-103CF | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 601- Drinking water. Right                    | 19221200-104DW | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 401- Classroom faucet. Left                   | 19221200-105CF | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 401-Drinking water. Right                     | 19221200-106DW | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 402- Classroom faucet. Left                   | 19221200-107CF | 3/12/2025 | 1.4 | Low        |  |  |  |
| 402- Drinking water. Right                    | 19221200-108DW | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 403- Classroom faucet. Left                   | 19221200-109CF | 3/12/2025 | 2.8 | Low        |  |  |  |
| 403-Drinking water. Right                     | 19221200-110DW | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 404-Classroom faucet. Left                    | 19221200-111CF | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 404- Drinking water. Right                    | 19221200-112DW | 3/12/2025 | ND  | Non-Detect |  |  |  |
|                                               |                | 3/12/2025 | 1   | Low        |  |  |  |
| 201- Classroom faucet. Right. Student Commons | 19221200-113CF |           |     |            |  |  |  |
|                                               |                | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 201- Classroom faucet. Left. Student Commons  | 19221200-114CF |           |     |            |  |  |  |
| 209-Single user restroom. Bathroom faucet     | 19221200-115BF | 3/12/2025 | ND  | Non-Detect |  |  |  |
| 210-Single user restroom. Bathroom faucet     | 19221200-116BF | 3/12/2025 | ND  | Non-Detect |  |  |  |
|                                               |                |           |     |            |  |  |  |