

Lead in Water Test Results Summary: Boones Ferry Primary

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
108- Nurses station faucet. Health room	19221200-001NS	3/12/2025	ND	Non-Detect			
109-Bathroom faucet. Nurses station bathroom	19221200-002BF	3/12/2025	ND	Non-Detect			
110- Staff faucet. Staff Lounge instant hot water. Left	19221200-003SF	3/12/2025	ND	Non-Detect			
110- Staff faucet. Staff Lounge. Right	19221200-004SF	3/12/2025	ND	Non-Detect			
112- Staff bathroom. Bathroom faucet. Left	19221200-005BF	3/12/2025	ND	Non-Detect			
111- Staff bathroom. Bathroom faucet. Right	19221200-006BF	3/12/2025	1.4	Low			
113- Work room. Staff faucet	19221200-007SF	3/12/2025	ND	Non-Detect			
Hall 121- Water bottle filler. Above fixture	19221200-008WB	3/12/2025	ND	Non-Detect			
19221200-009WC. Center	19221200-009WC	3/12/2025	ND	Non-Detect			
Hall 121- Water cooler- Located below 19221200-008WB. Right	19221200-010WC	3/12/2025	ND	Non-Detect			
Hall 121- Water cooler. Left	19221200-011SF	3/12/2025	ND	Non-Detect			
125- Media Office. Staff faucet	19221200-012KF	3/12/2025	ND	Non-Detect			
141- Kitchen faucet. West facing hand washing station. Right	19221200-014KF	3/12/2025	9.3	Moderate			
141- Kitchen faucet. Pot sprayer West facing. Left	19221200-015KF	3/12/2025	1.9	Low			
141- Kitchen faucet. Prep sink South facing	19221200-016KF	3/12/2025	ND	Non-Detect			
141- Kitchen faucet. Prep sink North facing. Right	19221200-017KF	3/12/2025	ND	Non-Detect			
141- Kitchen faucet. Prep sink North facing. Left	19221200-018BF	3/12/2025	1	Low			
147- Bathroom faucet. Toilet is off the kitchen	19221200-019BF	3/12/2025	ND	Non-Detect			
128- Girl's bathroom. Bathroom faucet	19221200-020BF	3/12/2025	ND	Non-Detect			
129- Boy's bathroom. Bathroom faucet	19221200-021BF	3/12/2025	ND	Non-Detect			
709- Toilet. Bathroom faucet	19221200-022BF	3/12/2025	ND	Non-Detect			
710- Toilet. Bathroom faucet	19221200-023CF	3/12/2025	3	Low			
701- Student Commons. Classroom faucet. Right	19221200-024CF	3/12/2025	ND	Non-Detect			
701- Student Commons. Classroom faucet. Left	19221200-025DW	3/12/2025	ND	Non-Detect			
801- Classroom drinking water. Right	19221200-026CF	3/12/2025	1.4	Low			
801- Classroom faucet. Left	19221200-027CF	3/12/2025	1.9	Low			
802- Classroom faucet. Left	19221200-028DW	3/12/2025	ND	Non-Detect			
802-Classroom drinking water. Right	19221200-029CF	3/12/2025	ND	Non-Detect			
803- Classroom faucet. Left	19221200-030DW	3/12/2025	ND	Non-Detect			
803-Classroom drinking water. Right	19221200-031CF	3/12/2025	1.3	Low			
804- Classroom faucet. Left	19221200-032DW	3/12/2025	ND	Non-Detect			
804-Classroom drinking water. Right	19221200-033BF	3/12/2025	ND	Non-Detect			
Between 715 Boys restroom and 716 Girls restroom. Bathroom faucet	19221200-034CF	3/12/2025	1.5	Low			
1001- Classroom faucet. Left	19221200-035DW	3/12/2025	ND	Non-Detect			
1001- Classroom drinking water	19221200-036CF	3/12/2025	1.4	Low			
1002- Classroom faucet. Left	19221200-037DW	3/12/2025	7.9	Moderate			
1002-Classroom drinking water. Right	19221200-038CF	3/12/2025	4.2	Low			
1003- Classroom faucet. Left	19221200-039DW	3/12/2025	ND	Non-Detect			
1003-Classroom drinking water							

1004- Classroom faucet. Left	19221200-040CF	3/12/2025	ND	Non-Detect			
1004- Classroom drinking water. Right	19221200-041DW	3/12/2025	ND	Non-Detect			
		3/12/2025	ND	Non-Detect			
726- Bathroom faucet. Staff bathroom in Gym 702	19221200-043BF						
Hall 721- Bathroom faucet. Located between Boys restroom 724 and Girls restroom 723	19221200-045BF	3/12/2025	4.4	Low			
Hall 721- Drinking water. Right	19221200-046DW	3/12/2025	ND	Non-Detect			
Between 706 Boys restroom and 707 Girls restroom. Bathroom faucet	19221200-048BF	3/12/2025	ND	Non-Detect			
1101- Classroom faucet. Left	19221200-049CF	3/12/2025	ND	Non-Detect			
1101- Drinking water. Right	19221200-050DW	3/12/2025	ND	Non-Detect			
1102- Classroom faucet. Left	19221200-051CF	3/12/2025	ND	Non-Detect			
1102- Drinking water. Right	19221200-052DW	3/12/2025	ND	Non-Detect			
1103- Classroom faucet. Left	19221200-053CF	3/12/2025	ND	Non-Detect			
1103- Drinking water. Right	19221200-054DW	3/12/2025	ND	Non-Detect			
1104- Classroom faucet. Left	19221200-055CF	3/12/2025	ND	Non-Detect			
1104- Drinking water. Right	19221200-056DW	3/12/2025	ND	Non-Detect			
901- Classroom faucet. Left	19221200-057CF	3/12/2025	3.1	Low			
901- Drinking water. Right	19221200-058DW	3/12/2025	ND	Non-Detect			
902- Classroom faucet. Left	19221200-059CF	3/12/2025	ND	Non-Detect			
902- Drinking water. Right	19221200-060DW	3/12/2025	ND	Non-Detect			
903 - Classroom faucet. Left	19221200-061CF	3/12/2025	ND	Non-Detect			
903- Drinking water. Right	19221200-062DW	3/12/2025	ND	Non-Detect			
904- Classroom faucet. Left	19221200-063CF	3/12/2025	ND	Non-Detect			
904- Drinking water. Right	19221200-064DW	3/12/2025	ND	Non-Detect			
703- Kitchen faucet. Satellite Kitchen. Hand washing sink	19221200-065KF	3/12/2025	ND	Non-Detect			
		3/12/2025	ND	Non-Detect			
703- Kitchen faucet. Satellite Kitchen. Prep sink	19221200-066KF						
701- Water cooler. Student commons. Right	19221200-067WC	3/12/2025	ND	Non-Detect			
701- Water cooler. Student commons. Left	19221200-068WC	3/12/2025	ND	Non-Detect			
201- Water cooler. Student commons. Right	19221200-069WC	3/12/2025	ND	Non-Detect			
201- Water cooler. Student commons. Left	19221200-070WC	3/12/2025	ND	Non-Detect			
203- Satellite kitchen. Kitchen faucet. Hand washing sink	19221200-071KF	3/12/2025	ND	Non-Detect			
		3/12/2025	1.7	Low			
203- Satellite kitchen. Kitchen faucet. Prep sink	19221200-072KF						
301- Classroom faucet. Left	19221200-073CF	3/12/2025	1	Low			
301- Drinking water. Right	19221200-074DW	3/12/2025	Nd	Non-Detect			
302- Classroom faucet. Left	19221200-075CF	3/12/2025	ND	Non-Detect			
302- Drinking water. Right	19221200-076DW	3/12/2025	ND	Non-Detect			
303- Classroom faucet. Left	19221200-077CF	3/12/2025	ND	Non-Detect			
303- Drinking water. Right	19221200-078DW	3/12/2025	ND	Non-Detect			
304- Classroom faucet. Left	19221200-079CF	3/12/2025	ND	Non-Detect			
304- Drinking water. Right	19221200-080DW	3/12/2025	ND	Non-Detect			
		3/12/2025	ND	Non-Detect			
Bathroom faucet. Between girl's 207 and boy's 206	19221200-081BF						
501- Classroom faucet. Left	19221200-082CF	3/12/2025	ND	Non-Detect			
501- Drinking water. Right	19221200-083DW	3/12/2025	ND	Non-Detect			
502- Classroom faucet. Left	19221200-084CF	3/12/2025	ND	Non-Detect			
502- Drinking water. Right	19221200-085DW	3/12/2025	ND	Non-Detect			
503- Classroom faucet. Left	19221200-086CF	3/12/2025	ND	Non-Detect			
503- Drinking water. Right	19221200-087DW	3/12/2025	1.3	Low			
504- Classroom faucet. Left	19221200-088CF	3/12/2025	ND	Non-Detect			
504- Drinking water. Right	19221200-089DW	3/12/2025	ND	Non-Detect			
		3/12/2025	1.5	Low			
221- Bathroom faucet. Staff bathroom. Single user	19221200-090BF						
222- Bathroom faucet. Girl's bathroom.	19221200-092BF	3/12/2025	3.8	Low			
Between boy's bathroom 223 and girl's bathroom		3/12/2025					
222. Drinking water. Left	19221200-094DW						
223- Bathroom faucet. Boy's bathroom	19221200-095BF	3/12/2025	ND	Non-Detect			
Bathroom faucet. Between Boy's 215 and Girl's 216	19221200-096BF	3/12/2025	ND	Non-Detect			
604- Classroom faucet. Left	19221200-097CF	3/12/2025	2.3	Low			
604- Drinking water. Right	19221200-098DW	3/12/2025	ND	Non-Detect			
603- Classroom faucet. Left	19221200-099CF	3/12/2025	9.2	Moderate			
603- Drinking water. Right	19221200-100DW	3/12/2025	17.1	Action Req.	4/18/2025	1.7	Low
602- Classroom faucet. Left	19221200-101CF	3/12/2025	1.1	Low			
602- Drinking water. Right	19221200-102DW	3/12/2025	ND	Non-Detect			

601- Classroom faucet. Left	19221200-103CF	3/12/2025	ND	Non-Detect			
601- Drinking water. Right	19221200-104DW	3/12/2025	ND	Non-Detect			
401- Classroom faucet. Left	19221200-105CF	3/12/2025	ND	Non-Detect			
401-Drinking water. Right	19221200-106DW	3/12/2025	ND	Non-Detect			
402- Classroom faucet. Left	19221200-107CF	3/12/2025	1.4	Low			
402- Drinking water. Right	19221200-108DW	3/12/2025	ND	Non-Detect			
403- Classroom faucet. Left	19221200-109CF	3/12/2025	2.8	Low			
403-Drinking water. Right	19221200-110DW	3/12/2025	ND	Non-Detect			
404-Classroom faucet. Left	19221200-111CF	3/12/2025	ND	Non-Detect			
404- Drinking water. Right	19221200-112DW	3/12/2025	ND	Non-Detect			
		3/12/2025	1	Low			
201- Classroom faucet. Right. Student Commons	19221200-113CF						
		3/12/2025	ND	Non-Detect			
201- Classroom faucet. Left. Student Commons	19221200-114CF						
209-Single user restroom. Bathroom faucet	19221200-115BF	3/12/2025	ND	Non-Detect			
210-Single user restroom. Bathroom faucet	19221200-116BF	3/12/2025	ND	Non-Detect			