

## Lead in Water Test Results Summary: Three Rivers Charter School

### Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.  
*Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.*
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

### Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Staff Toilet-Bathroom faucet. Main office behind the reception desk. Right	19221700-001BF	4/9/2025	0.6	Low			
Staff Toilet-Bathroom faucet. Main office behind the reception desk. Left	19221700-002BF	4/9/2025	ND	Non-Detect			
Staff room- Kitchen faucet. Staff room in main office	19221700-003SF	4/9/2025	ND	Non-Detect			
121-Boys Vestibule. Water bottle filler. Located with fixture# 19221700-005WC. Left	19221700-004WB	4/9/2025	ND	Non-Detect			
121- Boys Vestibule- Water cooler. Right. Located with fixture# 19221700-004WB	19221700-005WC	4/9/2025	ND	Non-Detect			
122- Boys Toilet. Bathroom faucet. Left	19221700-006BF	4/9/2025	ND				
122- Boys Toilet. Bathroom faucet. Left center	19221700-007BF	4/9/2025	1	Low			
122- Boys Toilet. Bathroom faucet. Right center	19221700-008BF	4/9/2025	1.4	Low			
122- Boys Toilet. Bathroom faucet. Right	19221700-009BF	4/9/2025	1.6	Low			
125- Kitchen. Kitchen faucet	19221700-010KF	4/9/2025	1.6	Low			
133- Girls Vestibule. Water bottle filler. Left	19221700-011WB	4/9/2025	ND	Non-Detect			
133- Girls Vestibule. Water cooler. Right	19221700-012WC	4/9/2025	ND	Non-Detect			
134- Girls Toilet. Bathroom faucet. Right	19221700-013BF	4/9/2025	ND	Non-Detect			
134- Girls Toilet. Bathroom faucet. Right center	19221700-014BF	4/9/2025	ND	Non-Detect			
134- Girls Toilet. Bathroom faucet. Left center	19221700-015BF	4/9/2025	ND	Non-Detect			
134- Girls Toilet. Bathroom faucet. Left	19221700-016BF	4/9/2025	ND	Non-Detect			