

Dear Sunset Families,

As part of the Oregon Health Authority's Healthy and Safe Schools Plan, Oregon schools are required to test the quality of drinking water every five years to ensure safety for staff and students. To ensure the safety of drinking water, a total of 91 water sources were tested at Sunset Primary School on December 20, 2019. Results were received on December 31, 2019, indicating all 91 test locations are below the permissible exposure limits for lead and copper. The actionable level for lead is 15 parts per billion, and the actionable level for copper is 1,300 parts per billion. For more information, or to view the full list of results, please visit the district website.