



Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6062330
Report Date: 07/12/2016
ORELAP #: OR100028
Project No: Sunset School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6062330 on 06/23/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed
Mark Leed
Client Services

Sample Results

Sample: 1-A		Collected: 06/23/16 06:19		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 110417		Received: 06/23/16 13:07		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.478	1.3	mg/L	0.0010	1	28768-24		07/11/16 11:11	
Lead	0.0013	0.015	mg/L	0.0002	1	28768-24		07/11/16 11:11	
Sample: 1-B		Collected: 06/23/16 06:20		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 110418		Received: 06/23/16 13:07		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.184	1.3	mg/L	0.0010	1	28768-25		07/11/16 11:13	
Lead	0.0003	0.015	mg/L	0.0002	1	28768-25		07/11/16 11:13	
Sample: 2-A		Collected: 06/23/16 06:24		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 110419		Received: 06/23/16 13:07		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.282	1.3	mg/L	0.0010	1	28768-26		07/11/16 11:15	
Lead	0.0009	0.015	mg/L	0.0002	1	28768-26		07/11/16 11:15	
Sample: 2-B		Collected: 06/23/16 06:25		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 110420		Received: 06/23/16 13:07		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.223	1.3	mg/L	0.0010	1	28768-27		07/11/16 11:16	
Lead	ND	0.015	mg/L	0.0002	1	28768-27		07/11/16 11:16	
Sample: 3-A		Collected: 06/23/16 06:28		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 110421		Received: 06/23/16 13:07		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.174	1.3	mg/L	0.0010	1	28768-28		07/11/16 11:18	
Lead	0.0005	0.015	mg/L	0.0002	1	28768-28		07/11/16 11:18	
Sample: 3-B		Collected: 06/23/16 06:29		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 110422		Received: 06/23/16 13:07		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.174	1.3	mg/L	0.0010	1	28768-29		07/11/16 11:20	
Lead	0.0011	0.015	mg/L	0.0002	1	28768-29		07/11/16 11:20	
Sample: 4-A		Collected: 06/23/16 06:31		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 110423		Received: 06/23/16 13:07		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.143	1.3	mg/L	0.0010	1	28768-30		07/11/16 11:22	

Lead	0.0002	0.015 mg/L	0.0002	1	28768-30	07/11/16 11:22
------	--------	------------	--------	---	----------	----------------

Sample: 4-B		Collected: 06/23/16 06:32				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110424		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.196	1.3	mg/L	0.0010	1	28768-31		07/11/16 11:24	
Lead	ND	0.015	mg/L	0.0002	1	28768-31		07/11/16 11:24	

Sample: 5-A		Collected: 06/23/16 06:34				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110425		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.172	1.3	mg/L	0.0010	1	28768-36		07/11/16 11:33	
Lead	0.0003	0.015	mg/L	0.0002	1	28768-36		07/11/16 11:33	

Sample: 5-B		Collected: 06/23/16 06:35				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110426		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.223	1.3	mg/L	0.0010	1	28768-37		07/11/16 11:35	
Lead	ND	0.015	mg/L	0.0002	1	28768-37		07/11/16 11:35	

Sample: 6-A		Collected: 06/23/16 06:38				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110427		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.141	1.3	mg/L	0.0010	1	28768-38		07/11/16 11:37	
Lead	0.0034	0.015	mg/L	0.0002	1	28768-38		07/11/16 11:37	

Sample: 6-B		Collected: 06/23/16 06:39				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110428		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.169	1.3	mg/L	0.0010	1	28768-39		07/11/16 11:39	
Lead	0.0033	0.015	mg/L	0.0002	1	28768-39		07/11/16 11:39	

Sample: Corridor 6-C		Collected: 06/23/16 06:41				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110429		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.159	1.3	mg/L	0.0010	1	28768-40		07/11/16 11:41	
Lead	ND	0.015	mg/L	0.0002	1	28768-40		07/11/16 11:41	

Sample: Teacher Workroom 1-A		Collected: 06/23/16 06:43				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110430		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0878	1.3	mg/L	0.0010	1	28768-41		07/11/16 11:43	
Lead	0.0014	0.015	mg/L	0.0002	1	28768-41		07/11/16 11:43	

Sample: Teacher Workroom 2-A		Collected: 06/23/16 06:44				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110431		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.342	1.3	mg/L	0.0010	1	28768-50	07/11/16 12:00
Lead	0.0284	0.015	mg/L	0.0002	1	28768-50	07/11/16 12:00

Sample: 7-A	Collected: 06/23/16 06:45	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110432	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.131	1.3	mg/L	0.0010	1	28768-42		07/11/16 11:44	
Lead	0.0007	0.015	mg/L	0.0002	1	28768-42		07/11/16 11:44	

Sample: 7-B	Collected: 06/23/16 06:46	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110433	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.243	1.3	mg/L	0.0010	1	28768-43		07/11/16 11:46	
Lead	ND	0.015	mg/L	0.0002	1	28768-43		07/11/16 11:46	

Sample: 8-A	Collected: 06/23/16 06:48	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110434	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0941	1.3	mg/L	0.0010	1	28768-44		07/11/16 11:48	
Lead	0.0003	0.015	mg/L	0.0002	1	28768-44		07/11/16 11:48	

Sample: 8-B	Collected: 06/23/16 06:49	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110435	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.250	1.3	mg/L	0.0010	1	28768-45		07/11/16 11:50	
Lead	ND	0.015	mg/L	0.0002	1	28768-45		07/11/16 11:50	

Sample: Healthroom 105-A	Collected: 06/23/16 06:51	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110436	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.366	1.3	mg/L	0.0010	1	28768-51		07/11/16 12:02	
Lead	0.0005	0.015	mg/L	0.0002	1	28768-51		07/11/16 12:02	

Sample: Restroom 106-A	Collected: 06/23/16 06:52	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110437	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.210	1.3	mg/L	0.0010	1	28768-52		07/11/16 12:04	
Lead	0.0003	0.015	mg/L	0.0002	1	28768-52		07/11/16 12:04	

Sample: Workroom 107-A	Collected: 06/23/16 06:53	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110438	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.159	1.3	mg/L	0.0010	1	28768-53		07/11/16 12:05	
Lead	0.0009	0.015	mg/L	0.0002	1	28768-53		07/11/16 12:05	

Sample: 11-A	Collected: 06/23/16 06:54	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110439	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.0530	1.3	mg/L	0.0010	1	28768-54	07/11/16 12:07
Lead	0.0012	0.015	mg/L	0.0002	1	28768-54	07/11/16 12:07

Sample: 11-B	Collected: 06/23/16 06:55	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110440	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0786	1.3	mg/L	0.0010	1	28768-55	07/11/16 12:09
Lead	0.0017	0.015	mg/L	0.0002	1	28768-55	07/11/16 12:09

Sample: 12-A	Collected: 06/23/16 06:56	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110441	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0727	1.3	mg/L	0.0010	1	28768-56	07/11/16 12:11
Lead	0.0013	0.015	mg/L	0.0002	1	28768-56	07/11/16 12:11

Sample: 12-B	Collected: 06/23/16 06:57	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110442	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0585	1.3	mg/L	0.0010	1	28768-57	07/11/16 12:13
Lead	0.0013	0.015	mg/L	0.0002	1	28768-57	07/11/16 12:13

Sample: 13-A	Collected: 06/23/16 06:58	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110443	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0634	1.3	mg/L	0.0010	1	28768-58	07/11/16 12:15
Lead	0.0015	0.015	mg/L	0.0002	1	28768-58	07/11/16 12:15

Sample: 13-B	Collected: 06/23/16 06:59	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110444	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0536	1.3	mg/L	0.0010	1	28768-59	07/11/16 12:17
Lead	0.0020	0.015	mg/L	0.0002	1	28768-59	07/11/16 12:17

Sample: Library A	Collected: 06/23/16 07:01	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110445	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.283	1.3	mg/L	0.0010	1	28768-64	07/11/16 12:27
Lead	0.0005	0.015	mg/L	0.0002	1	28768-64	07/11/16 12:27

Sample: Gym Corridor C-1	Collected: 06/23/16 07:03	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110446	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.266	1.3	mg/L	0.0010	1	28766-258	07/08/16 20:27
Lead	0.0003	0.015	mg/L	0.0002	1	28766-258	07/08/16 20:27

Sample: Gym Corridor C-2	Collected: 06/23/16 07:04	Temp: 22 C	Matrix: Drinking Water
Lab ID: 110447	Received: 06/23/16 13:07	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.288	1.3	mg/L	0.0010	1	28766-259		07/08/16 20:29	
Lead	0.0005	0.015	mg/L	0.0002	1	28766-259		07/08/16 20:29	
Sample: 204-A		Collected: 06/23/16 07:06			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110448		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.173	1.3	mg/L	0.0010	1	28766-260		07/08/16 20:31	
Lead	0.0017	0.015	mg/L	0.0002	1	28766-260		07/08/16 20:31	
Sample: 204-B		Collected: 06/23/16 07:07			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110449		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.675	1.3	mg/L	0.0010	1	28766-261		07/08/16 20:33	
Lead	0.0419	0.015	mg/L	0.0002	1	28766-261		07/08/16 20:33	
Sample: 38-A		Collected: 06/23/16 07:10			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110450		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0327	1.3	mg/L	0.0010	1	28768-65		07/11/16 12:29	
Lead	0.0133	0.015	mg/L	0.0002	1	28768-65		07/11/16 12:29	
Sample: 15-A		Collected: 06/23/16 07:11			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110451		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.176	1.3	mg/L	0.0010	1	28766-262		07/08/16 20:35	
Lead	0.0062	0.015	mg/L	0.0002	1	28766-262		07/08/16 20:35	
Sample: 15-B		Collected: 06/23/16 07:12			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110452		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.292	1.3	mg/L	0.0010	1	28766-263		07/08/16 20:37	
Lead	0.0019	0.015	mg/L	0.0002	1	28766-263		07/08/16 20:37	
Sample: 16-A		Collected: 06/23/16 07:13			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110453		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.136	1.3	mg/L	0.0010	1	28766-268		07/08/16 20:49	
Lead	0.0084	0.015	mg/L	0.0002	1	28766-268		07/08/16 20:49	
Sample: 16-B		Collected: 06/23/16 07:14			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110454		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.288	1.3	mg/L	0.0010	1	28768-66		07/11/16 12:31	
Lead	0.0035	0.015	mg/L	0.0002	1	28768-66		07/11/16 12:31	
Sample: 17-A		Collected: 06/23/16 07:15			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110455		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.147	1.3	mg/L	0.0010	1	28768-67		07/11/16 12:32	
Lead	0.0025	0.015	mg/L	0.0002	1	28768-67		07/11/16 12:32	
Sample: 17-B		Collected: 06/23/16 07:16			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110456		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.220	1.3	mg/L	0.0010	1	28768-68		07/11/16 12:34	
Lead	0.0012	0.015	mg/L	0.0002	1	28768-68		07/11/16 12:34	
Sample: 100 C-1		Collected: 06/23/16 07:16			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110457		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0315	1.3	mg/L	0.0010	1	28768-69		07/11/16 12:36	
Lead	0.0059	0.015	mg/L	0.0002	1	28768-69		07/11/16 12:36	
Sample: 19-A		Collected: 06/23/16 07:17			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110458		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.245	1.3	mg/L	0.0010	1	28768-70		07/11/16 12:38	
Lead	0.0084	0.015	mg/L	0.0002	1	28768-70		07/11/16 12:38	
Sample: 19-B		Collected: 06/23/16 07:18			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110459		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0498	1.3	mg/L	0.0010	1	28768-71		07/11/16 12:40	
Lead	0.0047	0.015	mg/L	0.0002	1	28768-71		07/11/16 12:40	
Sample: 20-A		Collected: 06/23/16 07:19			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110460		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.168	1.3	mg/L	0.0010	1	28768-72		07/11/16 12:42	
Lead	0.0023	0.015	mg/L	0.0002	1	28768-72		07/11/16 12:42	
Sample: 20-B		Collected: 06/23/16 07:20			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110461		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0896	1.3	mg/L	0.0010	1	28768-73		07/11/16 12:44	
Lead	0.0009	0.015	mg/L	0.0002	1	28768-73		07/11/16 12:44	
Sample: 21-A		Collected: 06/23/16 07:20			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110462		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.173	1.3	mg/L	0.0010	1	28768-78		07/11/16 12:56	
Lead	0.0057	0.015	mg/L	0.0002	1	28768-78		07/11/16 12:56	
Sample: 21-B		Collected: 06/23/16 07:21			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110463		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	1.30	1.3	mg/L	0.0010	1	28768-79		07/11/16 12:58	
Lead	0.166	0.015	mg/L	0.0002	1	28768-79		07/11/16 12:58	
Sample: 22-A		Collected: 06/23/16 07:22			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110464		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.152	1.3	mg/L	0.0010	1	28768-80		07/11/16 12:59	
Lead	0.0105	0.015	mg/L	0.0002	1	28768-80		07/11/16 12:59	
Sample: 22-B		Collected: 06/23/16 07:23			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110465		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.209	1.3	mg/L	0.0010	1	28768-81		07/11/16 13:01	
Lead	0.0064	0.015	mg/L	0.0002	1	28768-81		07/11/16 13:01	
Sample: 23-A		Collected: 06/23/16 07:25			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110466		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.162	1.3	mg/L	0.0010	1	28768-82		07/11/16 13:03	
Lead	0.0154	0.015	mg/L	0.0002	1	28768-82		07/11/16 13:03	
Sample: A100-C2		Collected: 06/23/16 07:26			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110467		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.465	1.3	mg/L	0.0010	1	28768-83		07/11/16 13:05	
Lead	0.0010	0.015	mg/L	0.0002	1	28768-83		07/11/16 13:05	
Sample: B105-A		Collected: 06/23/16 07:29			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110468		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.249	1.3	mg/L	0.0010	1	28768-84		07/11/16 13:07	
Lead	0.0014	0.015	mg/L	0.0002	1	28768-84		07/11/16 13:07	
Sample: S-1 Restroom 1-A		Collected: 06/23/16 07:33			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110469		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.260	1.3	mg/L	0.0010	1	28768-85		07/11/16 13:09	
Lead	0.0013	0.015	mg/L	0.0002	1	28768-85		07/11/16 13:09	
Sample: S-2 Restroom 1-A		Collected: 06/23/16 07:34			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110470		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.228	1.3	mg/L	0.0010	1	28768-86		07/11/16 13:11	
Lead	0.0006	0.015	mg/L	0.0002	1	28768-86		07/11/16 13:11	
Sample: B107-A		Collected: 06/23/16 07:30			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110471		Received: 06/23/16 13:07			Evidence of Cooling:N				

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.251	1.3	mg/L	0.0010	1	28768-87		07/11/16 13:13	
Lead	0.0014	0.015	mg/L	0.0002	1	28768-87		07/11/16 13:13	
Sample: B109-C		Collected: 06/23/16 07:32			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110472		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.264	1.3	mg/L	0.0080	20	28725-20	07/05/16 11:37	07/07/16 12:27	
Lead	0.0215	0.015	mg/L	0.0016	20	28725-20	07/05/16 11:37	07/07/16 12:27	
Sample: Kitchen B104 1-A		Collected: 06/23/16 07:36			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110473		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.139	1.3	mg/L	0.0010	1	28769-201		07/11/16 14:29	
Lead	0.0003	0.015	mg/L	0.0002	1	28769-201		07/11/16 14:29	
Sample: Kitchen B104 2-A		Collected: 06/23/16 07:37			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110474		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.242	1.3	mg/L	0.0010	1	28769-202		07/11/16 14:31	
Lead	0.0019	0.015	mg/L	0.0002	1	28769-202		07/11/16 14:31	
Sample: Wasewash B110-A		Collected: 06/23/16 07:37			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110475		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.119	1.3	mg/L	0.0010	1	28769-203		07/11/16 14:33	
Lead	0.0007	0.015	mg/L	0.0002	1	28769-203		07/11/16 14:33	
Sample: Cafeteria B103 1-A		Collected: 06/23/16 07:40			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110476		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.225	1.3	mg/L	0.0010	1	28769-204		07/11/16 14:35	
Lead	0.0093	0.015	mg/L	0.0002	1	28769-204		07/11/16 14:35	
Sample: Cafeteria B103 2-A		Collected: 06/23/16 07:41			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110477		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.210	1.3	mg/L	0.0010	1	28769-8		07/11/16 14:37	
Lead	0.0004	0.015	mg/L	0.0002	1	28769-8		07/11/16 14:37	
Sample: B101-A		Collected: 06/23/16 07:43			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 110478		Received: 06/23/16 13:07			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.143	1.3	mg/L	0.0010	1	28769-9		07/11/16 14:39	
Lead	0.0004	0.015	mg/L	0.0002	1	28769-9		07/11/16 14:39	
Sample: B101-B		Collected: 06/23/16 07:44			Temp: 22 C		Matrix: Drinking Water		

Lab ID: 110479		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.232	1.3	mg/L	0.0010	1	28769-10		07/11/16 14:40	
Lead	0.0028	0.015	mg/L	0.0002	1	28769-10		07/11/16 14:40	
Sample: B102-A		Collected: 06/23/16 07:45				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110480		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.278	1.3	mg/L	0.0010	1	28769-11		07/11/16 14:42	
Lead	0.0010	0.015	mg/L	0.0002	1	28769-11		07/11/16 14:42	
Sample: B102-B		Collected: 06/23/16 07:46				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110481		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.367	1.3	mg/L	0.0010	1	28769-12		07/11/16 14:44	
Lead	0.0024	0.015	mg/L	0.0002	1	28769-12		07/11/16 14:44	
Sample: 24-A		Collected: 06/23/16 07:52				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110482		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0424	1.3	mg/L	0.0010	1	28769-13		07/11/16 14:46	
Lead	0.0044	0.015	mg/L	0.0002	1	28769-13		07/11/16 14:46	
Sample: 24-B		Collected: 06/23/16 07:53				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110483		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0643	1.3	mg/L	0.0010	1	28769-18		07/11/16 14:55	
Lead	0.0069	0.015	mg/L	0.0002	1	28769-18		07/11/16 14:55	
Sample: 25-A		Collected: 06/23/16 08:14				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110484		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0444	1.3	mg/L	0.0010	1	28769-19		07/11/16 14:57	
Lead	0.0012	0.015	mg/L	0.0002	1	28769-19		07/11/16 14:57	
Sample: Storage (by Rm 24)-A		Collected: 06/23/16 07:55				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110485		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0288	1.3	mg/L	0.0010	1	28769-20		07/11/16 14:59	
Lead	0.0036	0.015	mg/L	0.0002	1	28769-20		07/11/16 14:59	
Sample: Corridor B002-C		Collected: 06/23/16 07:50				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 110486		Received: 06/23/16 13:07				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0445	1.3	mg/L	0.0010	1	28769-21		07/11/16 15:01	
Lead	0.0108	0.015	mg/L	0.0002	1	28769-21		07/11/16 15:01	

Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Lead & Copper

WJW

6662330

p. 1 of 3

Sunset School

Location/Site	Date Collected	Collector's Name	Time	Date Delivered	Lab I.D. Number	Lead Results	MCL	Copper Results	MCL
1-A	6/23/2016	Steve Matthias	6:19 AM	6/23/2016			0.02		1.3
1-B	6/23/2016	Steve Matthias	6:20 AM	6/23/2016					
2-A	6/23/2016	Steve Matthias	6:24 AM	6/23/2016					
2-B	6/23/2016	Steve Matthias	6:25 AM	6/23/2016					
3-A	6/23/2016	Steve Matthias	6:28 AM	6/23/2016					
3-B	6/23/2016	Steve Matthias	6:29 AM	6/23/2016					
4-A	6/23/2016	Steve Matthias	6:31 AM	6/23/2016					
4-B	6/23/2016	Steve Matthias	6:32 AM	6/23/2016					
5-A	6/23/2016	Steve Matthias	6:34 AM	6/23/2016					
5-B	6/23/2016	Steve Matthias	6:35 AM	6/23/2016					
6-A	6/23/2016	Steve Matthias	6:38 AM	6/23/2016					
6-B	6/23/2016	Steve Matthias	6:39 AM	6/23/2016					
Corridor 6-C	6/23/2016	Steve Matthias	6:41 AM	6/23/2016					
Teacher Workroom 1-A	6/23/2016	Steve Matthias	6:43 AM	6/23/2016					
Teacher Workroom 2-A	6/23/2016	Steve Matthias	6:44 AM	6/23/2016					
7-A	6/23/2016	Steve Matthias	6:45 AM	6/23/2016					
7-B	6/23/2016	Steve Matthias	6:46 AM	6/23/2016					
8-A	6/23/2016	Steve Matthias	6:48 AM	6/23/2016					
8-B	6/23/2016	Steve Matthias	6:49 AM	6/23/2016					
Healthroom 105-A	6/23/2016	Steve Matthias	6:51 AM	6/23/2016					
Restroom 106-A	6/23/2016	Steve Matthias	6:52 AM	6/23/2016					
Workroom 107-A	6/23/2016	Steve Matthias	6:53 AM	6/23/2016					
11--A	6/23/2016	Steve Matthias	6:54 AM	6/23/2016					
11-B	6/23/2016	Steve Matthias	6:55 AM	6/23/2016					

Steve Matthias

6/23/16 1307

22°C

m w/lead 6/23/16, 1307

Lead & Copper

WLWV

6062330

p. 2 of 3

12-A	6/23/2016	Steve Matthias	6:56 AM	6/23/2016					
12-B	6/23/2016	Steve Matthias	6:57 AM	6/23/2016					
13-A	6/23/2016	Steve Matthias	6:58 AM	6/23/2016					
13-B	6/23/2016	Steve Matthias	6:59 AM	6/23/2016					
Library A	6/23/2016	Steve Matthias	7:01 AM	6/23/2016					
Gym Corridor C-1	6/23/2016	Steve Matthias	7:03 AM	6/23/2016					
Gym Corridor C-2	6/23/2016	Steve Matthias	7:04 AM	6/23/2016					
204-A	6/23/2016	Steve Matthias	7:06 AM	6/23/2016					
204-B	6/23/2016	Steve Matthias	7:07 AM	6/23/2016					
38-A	6/23/2016	Steve Matthias	7:10 AM	6/23/2016					
15-A	6/23/2016	Steve Matthias	7:11 AM	6/23/2016					
15-B	6/23/2016	Steve Matthias	7:12 AM	6/23/2016					
16-A	6/23/2016	Steve Matthias	7:13 AM	6/23/2016					
16-B	6/23/2016	Steve Matthias	7:14 AM	6/23/2016					
17-A	6/23/2016	Steve Matthias	7:15 AM	6/23/2016					
17-B	6/23/2016	Steve Matthias	7:16 AM	6/23/2016					
100 C-1	6/23/2016	Steve Matthias	7:16 AM	6/23/2016					
19-A	6/23/2016	Steve Matthias	7:17 AM	6/23/2016					
19-B	6/23/2016	Steve Matthias	7:18 AM	6/23/2016					
20-A	6/23/2016	Steve Matthias	7:19 AM	6/23/2016					
20-B	6/23/2016	Steve Matthias	7:20 AM	6/23/2016					
21-A	6/23/2016	Steve Matthias	7:20 AM	6/23/2016					
21-B	6/23/2016	Steve Matthias	7:21 AM	6/23/2016					
22-A	6/23/2016	Steve Matthias	7:22 AM	6/23/2016					
22-B	6/23/2016	Steve Matthias	7:23 AM	6/23/2016					

Step / Math 6/23/16 1307

22°C

Mv Led 6/23/16, 1307

Lead & Copper

WLWV

6062330

p. 3 of 3

23-A	6/23/2016	Steve Matthias	7:25 AM	6/23/2016					
A100-C2	6/23/2016	Steve Matthias	7:26 AM	6/23/2016					
B105-A	6/23/2016	Steve Matthias	7:29 AM	6/23/2016					
S-1 Restroom 1-A	6/23/2016	Steve Matthias	7:33 AM	6/23/2016					
S-2 Restroom 1-A	6/23/2016	Steve Matthias	7:34 AM	6/23/2016					
B107-A	6/23/2016	Steve Matthias	7:30 AM	6/23/2016					
B109-C	6/23/2016	Steve Matthias	7:32 AM	6/23/2016					
Kitchen B104 1-A	6/23/2016	Steve Matthias	7:36 AM	6/23/2016					
Kitchen B104 2-A	6/23/2016	Steve Matthias	7:37 AM	6/23/2016					
Warewash B110-A	6/23/2016	Steve Matthias	7:37 AM	6/23/2016					
Cafeteria B103 1-A	6/23/2016	Steve Matthias	7:40 AM	6/23/2016					
Cafeteria B103 2-A	6/23/2016	Steve Matthias	7:41 AM	6/23/2016					
B101-A	6/23/2016	Steve Matthias	7:43 AM	6/23/2016					
B101-B	6/23/2016	Steve Matthias	7:44 AM	6/23/2016					
B102-A	6/23/2016	Steve Matthias	7:45 AM	6/23/2016					
B102-B	6/23/2016	Steve Matthias	7:46 AM	6/23/2016					
24-A	6/23/2016	Steve Matthias	7:52 AM	6/23/2016					
24-B	6/23/2016	Steve Matthias	7:53 AM	6/23/2016					
25-A	6/23/2016	Steve Matthias	8:14 AM	6/23/2016					
Storage (by Rm 24)-A	6/23/2016	Steve Matthias	7:55 AM	6/23/2016					
Corridor B002-C	6/23/2016	Steve Matthias	7:50 AM	6/23/2016					

Steve Matthias 6/23/16 1307

22°C

M Wied 6/23/16, 1307